ing. Fausto Falco
UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 1.
Quartiere S.Elia - Brindisi

T_A 20°C T_F 2 °C

Edificio tipo 2 in linea - Corpo A
cif. planim. 4CB-5CB

Piano 2°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	r	ΔT	Aum. %	Cal/h	mq.	n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	N	3,80 x 3,0	11,40	1,2	18	1,30	320		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	Vol. 3,8 x 3,85 x 3,0 = 44 x 0,3 x 18							237		
								1019	2,68	1
2	parete	N	3,7 x 3,0	11,10	1,2	18	1,30	312		
	parete	W	3,6 x 3,0	10,80	1,2	18	1,20	280		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	Vol 3,55 x 3,7 x 3,0 = 39 x 0,3 x 18							213		
								944	2,50	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	S	1,0 x 3,0	3,00	1,2	18	1,15	75		
	finestra	S	0,6 x 1,15	0,69	3,8	18	1,15	54		
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							105		
								372	1,00	1
4	parete	W	2,4 x 3,0	7,20	1,2	18	1,15	179		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Vol 3,7 x 2,4 x 3,0 = 27 x 0,3 x 18							144		
								456	1,20	1.
5	parete	E	3,65 x 3,0	10,95	1,2	18	1,25	296		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	145		
	parete	N	2,0 x 3,0	6,00	1,2	18	1,30	168		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	Vol. 4,0 x 3,5 x 3,0 = 42 x 0,3 x 18							227		
								1162	3,05	1
6	parete	W	4,8 x 3,0	14,40	1,2	18	1,15	358		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int.		2,5 x 3,0	7,50	1,4	10		105		
	Vol 3,7 x 4,5 x 3,0 = 50 x 0,3 x 18							270		
								998	2,62	1.
7	parete int		1,6 x 3,0	4,80	1,4	10		67		
	porta int		1,05 x 2,25	2,36	1,6	10		38		
	volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								152	0,40	1.

ing Fausto Falco
UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 1
Quartiere S.Elia - Brindisi

T_A 20°C T_E 2 °C

Edificio tipo 2 in linea - Corpo A
cif. planim. 4CB - 5CB

Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	N	3,80 x 3,0	11,40	1,2	18	1,30	320		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	Vol. 3,8 x 3,85 x 3,0 = 44 x 0,3 x 18							237		
								1019	2,68	1
2	parete	N	3,7 x 3,0	11,10	1,2	18	1,30	312		
	parete	W	3,6 x 3,0	10,80	1,2	18	1,20	280		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol 3,55 x 3,7 x 3,0 = 39 x 0,3 x 18							213		
								944	2,50	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	S	1,0 x 3,0	3,00	1,2	18	1,15	75		
	finestra	S	0,6 x 1,15	0,69	3,8	18	1,15	54		
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							105		
								372	1,00	1
4	parete	W	2,4 x 3,0	7,20	1,2	18	1,15	179		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Vol 3,7 x 2,4 x 3,0 = 27 x 0,3 x 18							144		
								456	1,20	1
5	parete	E	3,65 x 3,0	10,95	1,2	18	1,25	296		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	145		
	parete	N	2,0 x 3,0	6,00	1,2	18	1,30	168		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	Vol. 4,0 x 3,5 x 3,0 = 42 x 0,3 x 18							227		
								1162	3,05	1
6	parete	W	4,8 x 3,0	14,40	1,2	18	1,15	358		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int.		2,5 x 3,0	7,50	1,4	10		105		
	Vol 3,7 x 4,5 x 3,0 = 50 x 0,3 x 18							270		
								998	2,62	1
7	parete int		1,6 x 3,0	4,80	1,4	10		67		
	porta int		1,05 x 2,25	2,36	1,6	10		38		
	Volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								152	0,40	1

ing. Fausto Falin
UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 1
Quartiere S.Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tip 2 in linea - Corpo A
rif. planim. 4CB-5CB

Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	N	3,80 x 3,0	11,40	1,2	18	1,30	320		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	Vol. 3,8 x 3,85 x 3,0 = 44 x 0,3 x 18							237		
								1019	2,68	1
2	parete	N	3,7 x 3,0	11,10	1,2	18	1,30	312		
	parete	W	3,6 x 3,0	10,80	1,2	18	1,20	280		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	Vol 3,55 x 3,7 x 3,0 = 39 x 0,3 x 18							213		
								944	2,56	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	S	1,0 x 3,0	3,00	1,2	18	1,15	75		
	finestra	S	0,6 x 1,15	0,69	3,8	18	1,15	54		
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							105		
								372	1,00	1
4	parete	W	2,4 x 3,0	7,20	1,2	18	1,15	179		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Vol 3,7 x 2,4 x 3,0 = 27 x 0,3 x 18							144		
								456	1,20	1
5	parete	E	3,65 x 3,0	10,95	1,2	18	1,25	296		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	145		
	parete	N	2,0 x 3,0	6,00	1,2	18	1,30	168		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	Vol. 4,0 x 3,5 x 3,0 = 42 x 0,3 x 18							227		
								1162	3,05	1
6	parete	W	4,8 x 3,0	14,40	1,2	18	1,15	358		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int.		2,5 x 3,0	7,50	1,4	10		105		
	Vol 3,7 x 4,5 x 3,0 = 50 x 0,3 x 18							270		
								998	2,62	1
7	parete int		1,6 x 3,0	4,80	1,4	10		67		
	porta int		1,05 x 2,25	2,36	1,6	16		38		
	volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								152	0,40	1

S.T.I.	Ing Fausto Falco UFFICIO TECNICO	Progetto N. 704 Fascicolo A	Pag. 2
		Quartiere S. Elia - Brindisi	

T_A 20°C T_F 2°C — Edificio tipo 2 in linea - Corpo A, rif. planim. 4CB-5CB — Piano 2°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	F	ΔT	Aum. %	Cal/h	mq.	n.
9	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,00	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	volume 4,1 x 3,6 x 3 = 44 x 0,3 x 18							239		
								1173	3,10	1
10	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestre	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	volume 3,7 x 5,2 x 3 = 58 x 0,3 x 18							312		
								1092	2,88	1
11	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	vol. 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								193	0,50	1
12	come 3		vol 19					372	1,00	1
13	parete	N	1,0 x 3,0	3,00	1,2	18	1,30	84		
	parete	W	2,7 x 3,0	8,10	1,2	18	1,20	210		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol 2,7 x 4,8 x 3,0 = 39 x 0,3 x 18							210		
								643	1,70	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol. 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								655	1,75	1
15	parete	W	3,7 x 3,0	11,10	1,2	18	1,15	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	vol 3,7 x 4,8 x 3,0 = 53 x 0,3 x 18							288		
								697	1,85	1
8	come 7		vol 9					152	0,40	1

Ing Fausto Falco

Quartiere S. Elia - Brindisi

T_A 20°C T_E 2°C

Edificio tipo 2 in linea - Corpo A
rif. planim. 4 CB - 5 CB

Piano 2°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
9	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,00	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	Volume 4,1 x 3,6 x 3 = 44 x 0,3 x 18							239		
								1173	3,10	1
10	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestre	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	volume 3,7 x 5,2 x 3 = 58 x 0,3 x 18							312		
								1092	2,88	1
11	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	vol 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								193	0,50	1
12	come 3		vol 19					372	1,00	1
13	parete	N	1,0 x 3,0	3,00	1,2	18	1,30	84		
	parete	W	2,7 x 3,0	8,10	1,2	18	1,20	210		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol 2,7 x 4,8 x 3,0 = 39 x 0,3 x 18							210		
								643	1,70	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								655	1,75	1
15	parete	W	3,7 x 3,0	11,10	1,2	18	1,15	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	vol 3,7 x 4,8 x 3,0 = 53 x 0,3 x 18							288		
								697	1,85	1
8	come 7		vol 9					152	0,40	1

S.T.I. — UFFICIO TECNICO — Ing. Fausto Falisa

Progetto N. 704 Fascicolo A Pag. 2

Quartiere S. Elia - Brindisi

T_A 20°C T_E 2°C — Edificio tipo 2 in linea - Corpo A — rif. planim. 4CB-5CB — Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,00	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	Volume 4,1 x 3,6 x 3 = 44 x 0,3 x 18							239		
								1173	3,10	1
10	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestre	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	volume 3,7 x 5,2 x 3 = 58 x 0,3 x 18							312		
								1092	2,88	1
11	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	vol. 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								193	0,50	1
12	come 3		vol 19					372	1,00	1
13	parete	N	1,0 x 3,0	3,00	1,2	18	1,30	84		
	parete	W	2,7 x 3,0	8,10	1,2	18	1,20	210		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol 2,7 x 4,8 x 3,0 = 39 x 0,3 x 18							210		
								643	1,70	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol. 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								655	1,75	1
15	parete	W	3,7 x 3,0	11,10	1,2	18	1,15	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	vol 3,7 x 4,8 x 3,0 = 53 x 0,3 x 18							288		
								697	1,85	1
8	come 7		vol 9					152	0,40	1

Quattiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
zif. planim. 4CB - 5CB

Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. α	Cal/h	Stufe mq.	Stufe n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	S	3,80 x 3,0	11,40	1,2	18	1,15	283		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Volume 3,85 x 3,8 x 3,0 = 44 x 0,3 x 18							237		
								965	2,55	1
2	parete	S	3,70 x 3,0	11,10	1,2	18	1,15	276		
	parete	W	3,55 x 3,0	10,65	1,2	18	1,20	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	Vol. 3,55 x 3,7 x 3,0 = 39 x 0,3 x 18							213		
								904	2,40	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	N	1,0 x 3,0	3,0	1,2	18	1,30	75		
	finestra	N	0,6 x 1,15	0,69	3,8	18	1,30	54		
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							198		
								372	1,00	1
4	parete	W	2,4 x 3,0	7,2	1,2	18	1,15	179		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Volume 2,4 x 3,7 x 3,0 = 27 x 0,3 x 18							144		
								456	1,20	1
5	parete	W	4,8 x 3,0	14,40	1,2	18	1,15	358		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	par. int		2,5 x 3,0	7,5	1,4	10		105		
	Vol 4,8 x 3,7 x 3,0 = 53 x 0,3 x 18							288		
								1016	2,65	1
6	parete int		1,6 x 3,0	4,8	1,4	10		67		
	porta int		1,05 x 2,25	2,36	1,6	10		38		
	vol. 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								152	0,40	1
7	parete	E	3,65 x 3,0	10,95	1,2	18	1,25	296		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	145		
	parete	S	1,7 x 3,0	5,10	1,2	18	1,15	127		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	par. int		4,2 x 3,0	12,6	1,4	10		176		
	vol. 4,0 x 3,5 x 3,0 = 42 x 0,3 x 18							227		
								1104	2,90	1

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
rif. planim. 4CB - 5CB

Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	S	3,80 x 3,0	11,40	1,2	18	1,15	283		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Volume 3,85 x 3,8 x 3,0 = 44 x 0,3 x 18							237		
								965	2,55	1
2	parete	S	3,70 x 3,0	11,10	1,2	18	1,15	276		
	parete	W	3,55 x 3,0	10,65	1,2	18	1,20	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	Vol. 3,55 x 3,7 x 3,0 = 39 x 0,3 x 18							213		
								904	2,40	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	N	1,0 x 3,0	3,0	1,2	18	1,30	75		
	finestra	N	0,6 x 1,15	0,69	3,8	18	1,30	54		
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							198		
								372	1,00	1
4	parete	W	2,4 x 3,0	7,2	1,2	18	1,15	179		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	Volume 2,4 x 3,7 x 3,0 = 27 x 0,3 x 18							144		
								456	1,20	1
5	parete	W	4,8 x 3,0	14,40	1,2	18	1,15	358		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	par. int.		2,5 x 3,0	7,5	1,4	10		105		
	Vol 4,8 x 3,7 x 3,0 = 53 x 0,3 x 18							288		
								1016	2,65	1
6	parete int		1,6 x 3,0	4,8	1,4	10		67		
	porta int		1,05 x 2,25	2,36	1,6	10		38		
	vol. 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								152	0,40	1
7	parete	E	3,65 x 3,0	10,95	1,2	18	1,25	296		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	145		
	parete	S	1,7 x 3,0	5,10	1,2	18	1,15	127		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	par. int		4,2 x 3,0	12,6	1,4	10		176		
	vol. 4,0 x 3,5 x 3,0 = 44 x 0,3 x 18							227		
								1104	2,90	1

S.T.I. UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 4

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
rif. planim. 4CB - 5CB

Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	come 7		Vol 44					1104	2,90	1
10	come 6 p. 2°		Vol 58					1092	2,85	1
11	come 5 p. 2°		Vol 9					193	0,50	1
12	come 3		Vol 19					372	1,00	1
13	come 13	p. 2°	Vol 39					643	1,70	1
14	come 14	p. 2°	Vol 42					655	1,75	1
15	come 15	p. 2°	Vol 53					697	1,85	1
16	come 6		Vol 9					152	0,40	1
	Totale piano		2°	Vol	1011			19.957	52,68	30

S.I. Infanto Elio
UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 4

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
rif. planim. 4CB - 5CB

Piano 2°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	come 7		Vol 44					1104	2,90	1
10	come 6 p. 2°		Vol 58					1092	2,85	1
11	come 5 p. 2°		Vol 9					193	0,50	1
12	come 3		Vol 19					372	1,00	1
13	come 13	p. 2°	Vol 39					643	1,70	1
14	come 14	p. 2°	Vol 42					655	1,75	1
15	come 15	p 2°	Vol 53					697	1,85	1
16	come 6		Vol 9					152	0,40	1
	Totale piano		2°	Vol	1011			19.957	52.68	30

T_A 20°C T_F 2°C — Edificio tip 2 in linea - Corpo A — zif planim. 4CB - 5CB — Piano 3°

Locali n°	struttura	esp.	Dimensioni							Stufe n.
1	parete	N	3,8 x 3,0	11,40	1,2	18	1,30	320		
	parete	E	3,7 x 3,0	11,10	1,2	18	1,25	300		
	finestra	N	0,75 x 2,25	1,69	3,8	18	1,30	150		
	volume 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								998	2,65	1
2	parete	N	4,8 x 3,0	14,40	1,2	18	1,30	404		
	parete	W	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	volume 4,8 x 3,7 x 3,0 = 53 x 0,3 x 18							288		
								1119	2,90	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	S	1,0 x 3,0	3,00	1,2	18	1,15	75		
	finestra	S	0,6 x 1,15	0,69	3,8	18	1,15	54		
	vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							105		
								372	1,00	1
4	parete	W	2,7 x 3,0	7,2	1,2	18	1,15	179		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	vol 2,7 x 4,8 x 3,0 = 39 x 0,3 x 18							210		
								522	1,37	1
5	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	vol 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								193	0,50	1
6	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,50 x 3,0	7,5	1,4	10		105		
	volume 3,7 x 5,2 x 3,0 = 58 x 0,3 x 18							312		
								1092	2,88	1
7	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,00	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,20 x 3,0	12,6	1,4	10		176		
	volume 4,1 x 3,6 x 3,0 = 44 x 0,3 x 18							239		
								1173	3,10	1
7b	parete int		1,6 x 3,0	4,80	1,4	10		67		
	porta int		1,05 x 2,25	2,36	1,6	10		38		
	volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								152	0,40	1

T_A 20°C T_F 2°C — Edificio tipo 2 in linea - Corpo A — rif. planim. 4CB - 5CB — Piano 3°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	Δt	Aum. α	Cal/h	Stufe mq.	Stufe n.
9	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,00	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	Volume 4,1 x 3,6 x 3 = 44 x 0,3 x 18							239		
								1173	3,10	1
10	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestre	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	volume 3,7 x 5,2 x 3 = 58 x 0,3 x 18							312		
								1092	2,88	1
11	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	vol. 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								193	0,50	1
12	come 3		vol 19					372	1,00	1
13	parete	N	1,0 x 3,0	3,00	1,2	18	1,30	84		
	parete	W	2,7 x 3,0	8,10	1,2	18	1,20	210		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol 2,7 x 4,8 x 3,0 = 39 x 0,3 x 18							210		
								643	1,70	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol. 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								655	1,75	1
15	parete	W	3,7 x 3,0	11,10	1,2	18	1,15	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	vol 3,7 x 4,8 x 3,0 = 53 x 0,3 x 18							288		
								697	1,85	1
8	come 7		vol 9					152	0,40	1

Quartiere S. Elia - Brindisi

Edificio tipo 2 in linea - Corpo A
cif. planim. 4CB - 5CB

T_A 20°C T_E 2°C — Piano 3°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	V	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,00	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,6	1,4	10		176		
	volume 4,1 x 3,6 x 3 = 44 x 0,3 x 18							239		
								1173	3,10	1
10	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	volume 3,7 x 5,2 x 3 = 58 x 0,3 x 18							312		
								1092	2,88	1
11	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	vol. 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								193	0,50	1
12	come 3		vol 19					372	1,00	1
13	parete	N	1,0 x 3,0	3,00	1,2	18	1,30	84		
	parete	W	2,7 x 3,0	8,10	1,2	18	1,20	210		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol. 2,7 x 4,8 x 3,0 = 39 x 0,3 x 18							210		
								643	1,70	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	vol. 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								655	1,75	1
15	parete	W	3,7 x 3,0	11,10	1,2	18	1,15	276		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	vol 3,7 x 4,8 x 3,0 = 53 x 0,3 x 18							288		
								697	1,85	1
8	come 7		vol 9					152	0,40	1

T_A 20°C T_F 2°C — Edificio tipo 2 in linea - Corpo A — rif. planim. 4CB - 5CB — Piano 3°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	parete	E	4.1 x 3.0	12.30	1.2	18	1.25	332		
	finestra	E	0.75 x 2.25	1.69	3.8	18	1.25	144		
	parete	S	2.0 x 3.0	6.00	1.2	18	1.15	149		
	finestra	S	0.75 x 2.25	1.69	3.8	18	1.15	133		
	parete int.		4.2 x 3.0	12.6	1.4	10		176		
	Volume 4.1 x 3.6 x 3 = 44 x 0.3 x 18							239		
								1173	3.10	1
10	parete	W	5.5 x 3.0	16.50	1.2	18	1.15	410		
	finestre	W	2 x 0.75 x 2.25	3.38	3.8	18	1.15	265		
	parete int		2.5 x 3.0	7.5	1.4	10		105		
	volume 3.7 x 5.2 x 3 = 58 x 0.3 x 18							312		
								1092	2.88	1
11	parete	E	1.1 x 3.0	3.30	1.2	18	1.20	86		
	finestra	E	0.6 x 1.15	0.69	3.8	18	1.20	57		
	vol. 1.1 x 2.8 x 3.0 = 9 x 0.3 x 18							50		
								193	0.50	1
12	come 3		vol 19					372	1.00	1
13	parete	N	1.0 x 3.0	3.00	1.2	18	1.30	84		
	parete	W	2.7 x 3.0	8.10	1.2	18	1.20	210		
	finestra	W	0.75 x 2.25	1.69	3.8	18	1.20	139		
	vol 2.7 x 4.8 x 3.0 = 39 x 0.3 x 18							210		
								643	1.70	1
14	parete	E	3.7 x 3.0	11.10	1.2	18	1.20	288		
	finestra	E	0.75 x 2.25	1.69	3.8	18	1.20	139		
	vol. 3.7 x 3.8 x 3.0 = 42 x 0.3 x 18							228		
								655	1.75	1
15	parete	W	3.7 x 3.0	11.10	1.2	18	1.15	276		
	finestra	W	0.75 x 2.25	1.69	3.8	18	1.15	133		
	vol 3.7 x 4.8 x 3.0 = 53 x 0.3 x 18							288		
								697	1.85	1
8	come 7		vol 9					152	0.40	1

S.T. UFFICIO TECNICO

704 A 7

Quartiere S. Elia - Brindisi

Edificio tipo 2 in linea - corpo B
zil. planim. 4CB - 5CB

T_e 20°C T_m 2°C ΔT_{max} 30

	Strutture	esp.	Dimensioni mt	mq				Stufe mq	n°
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312	
	parete	S	3,80 x 3,0	11,40	1,2	18	1,15	283	
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133	
	Volume 3,85 x 3,8 x 3,0 = 44 x 0,3 x 18							237	
								965	2,55 1
2	parete	S	3,70 x 3,0	11,10	1,2	18	1,15	276	
	parete	W	3,55 x 3,0	10,65	1,2	18	1,20	276	
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139	
	Vol 3,55 x 3,7 x 3,0 = 39 x 0,3 x 18							213	
								904	2,40 1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138	
	parete	N	1,0 x 3,0	3,0	1,2	18	1,30	75	
	finestra	N	0,6 x 1,15	0,69	3,8	18	1,30	54	
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							198	
								372	1,00 1
4	parete	W	2,4 x 3,0	7,2	1,2	18	1,15	179	
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133	
	volume 2,4 x 3,7 x 3,0 = 27 x 0,3 x 18							144	
								456	1,20 1
5	parete	W	4,8 x 3,0	14,40	1,2	18	1,15	358	
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265	
	parz. int.		2,5 x 3,0	7,5	1,4	10		105	
	Vol 4,8 x 3,7 x 3,0 = 53 x 0,3 x 18							288	
								[illegible]	2,65 1
6	parete int		1,6 x 3,0	4,8	1,4	10		67	
	porta int		1,05 x 2,25	2,36	1,6	10		38	
	Vol. 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47	
								152	0,40 1
7	parete	E	3,65 x 3,0	10,95	[illegible]	[illegible]	[illegible]	[illegible]	
	finestra	E	0,75 x [illegible]	1,69	[illegible]	[illegible]	[illegible]	[illegible]	
	parete	S	1,7 x 3,0	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133	
	[illegible] int		[illegible] x 3	[illegible]	[illegible]	[illegible]		[illegible]	
	[illegible] x 3,5 x [illegible] = [illegible]							[illegible]	
								[illegible]	2,90 1

Quartiere S. Elia - Brindisi

Edificio tipo 2 in linea - corpo B
vil. blocchi 4CB - 5CB

1	parete	E	3,85 × 3,0	11,55	1,2	18	1,25	312		
	parete	S	3,80 × 3,0	11,40	1,2	18	1,15	283		
	finestra	S	0,75 × 2,25	1,69	3,8	18	1,15	133		
	Volume 3,85 × 3,8 × 3,0 = 44 × 0,3 × 18							237		
								965	2,55	1
2	parete	S	3,70 × 3,0	11,10	1,2	18	1,15	276		
	parete	W	3,55 × 3,0	10,65	1,2	18	1,20	276		
	finestra	W	0,75 × 2,25	1,69	3,8	18	1,20	139		
	Vol 3,55 × 3,7 × 3,0 = 39 × 0,3 × 18							213		
								904	2,40	1
3	parete	E	1,7 × 3,0	5,10	1,2	18	1,25	138		
	parete	N	1,0 × 3,0	3,0	1,2	18	1,30	75		
	finestra	N	0,6 × 1,15	0,69	3,8	18	1,30	54		
	Vol 1,7 × 3,8 × 3,0 = 19 × 0,3 × 18							198		
								372	1,00	1
4	parete	W	2,4 × 3,0	7,2	1,2	18	1,15	179		
	finestra	W	0,75 × 2,25	1,69	3,8	18	1,15	133		
	volume 2,4 × 3,7 × 3,0 = 27 × 0,3 × 18							144		
								456	1,20	1
5	parete	W	4,8 × 3,0	14,40	1,2	18	1,15	358		
	finestra	W	2 × 0,75 × 2,25	3,38	3,8	18	1,15	265		
	bar. int		2,5 × 3,0	7,5	1,4	10		105		
	Vol 4,8 × 3,7 × 3,0 = 53 × 0,3 × 18							288		
								1016	2,65	1
6	parete int		1,6 × 3,0	4,8	1,4	10		67		
	porta int		1,05 × 2,25	2,36	1,6	10		38		
	vol. 1,6 × 1,8 × 3,0 = 9 × 0,3 × 18							47		
								152	0,40	1
7	parete	E	3,65 × 3,0	10,95	1,2	18	1,25	296		
	finestra	E	0,75 × 2,25	1,69	3,8	18	1,25	145		
	parete	S	1,7 × 3,0	5,10	1,2	18	1,15	127		
	finestra	S	0,75 × 2,25	1,69	3,8	18	1,15	133		
	bar int		4,2 × 3,0	12,6	1,4	10		176		
	vol 4,0 × 3,5 × 3,0 = 42 × 0,3 × 18							227		
								1104	2,90	1

Quartiere S. Elia - Brindisi

Edificio tipo 2 in linea - corpo B
rif. planim. 4CB - 5CB

20	2					3°
9	come 3	vol 41		154	2,90	1
10	come 1 p. 3°	vol 50		1092	2,85	1
11	come 1 p. 3°			193	0,50	1
12	come 3	vol 19		372	1,00	1
13	come 13	p. 2°	vol 39	643	1,70	1
14	come 14	p. 2°	vol 42	655	1,75	1
15	come 15	p 2°	vol 53	697	1,85	1
16	come 6		vol 9	152	0,40	1
	Totale piano	3°	vol 1054	20475	53,93	31

Edificio tipo 2 in linea - corpo B
20 2 rif. planim. 4CB - 5CB 3°

9	come 7	vol 44		154	2,90	1
10	come 8 p. 2°	vol 40		1092	2,85	1
11	come 2 p. 2°	vol 1		193	0,50	1
12	come 3	vol 14		372	1,00	1
13	come 13	p. 2°	vol 39	643	1,70	1
14	come 14	p. 2°	vol 42	655	1,75	1
15	come 15	p 2°	vol 53	697	1.85	1
16	come 6		vol 9	152	0,40	1
	Totale piano 3°	vol	1054	20.475	53,93	31

S.I.I. — Ing. Franco Falco — UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 9

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo A
rif. planim. 4CB - 5CB

Piano 1°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	come 1	p. 3°						998		
	pavimento		3.7 x 3.8	14.06	1.4	18		354		
	vol 42							1352	3.55	1
2	come 2	p. 3°						1119		
	pavimento		4.8 x 3.7	17.76	1.4	18		448		
	vol 53							1567	4.15	1
3	come 3	p. 3°						372		
	pavimento		1.7 x 3.8	6.46	1.4	18		163		
	vol 19							535	1.40	1
4	come 4	p. 3°						522		
	pavimento		2.7 x 4.8	12.96	1.4	18		327		
	vol 39							849	2.25	1
5	come 5	p. 3°						193		
	pavimento		1.1 x 2.8	3.08	1.4	18		78		
	vol 9							271	0.70	1
6	come 6	p. 3°						1092		
	pavimento		3.7 x 5.2	19.24	1.4	18		484		
	vol 58							1576	4.15	1
7	come 7	p. 3°						1173		
	pavimento		4.1 x 3.6	14.76	1.4	18		372		
	vol 44							1545	4.15	1
7b	come 7b	p. 3°						132		
	pavimento		1.6 x 1.8	2.88	1.4	18		73		
	vol 9							205	0.55	1

S.I.

Ing Fausto Falco
UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 9

Quartiere S. Elia - Brindisi

TA 20°C TE 2°C

Edificio tipo 2 in linea - corpo A
rif. planim. 4CB - 5CB

Piano 1°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
1	come 1	p. 3°						998		
	pavimento		3,7 x 3,8	14,06	1,4	18		354		
	vol 42							1352	3,55	1
2	come 2	p 3°						1119		
	pavimento		4,8 x 3,7	17,76	1,4	18		448		
	vol 53							1567	4,15	1
3	come 3	p 3°						372		
	pavimento		1,7 x 3,8	6,46	1,4	18		163		
	vol 19							535	1,40	1
4	come 4	p. 3°						522		
	pavimento		2,7 x 4,8	12,96	1,4	18		327		
	vol 39							849	2,25	1
5	come 5	p. 3°						193		
	pavimento		1,7 x 2,8	3,08	1,4	18		78		
	vol 9							271	0,70	1
6	come 6	p. 3°						1092		
	pavimento		3,7 x 5,2	19,24	1,4	18		484		
	vol 58							1576	4,15	1
7	come 7	p 3°						1173		
	pavimento		4,1 x 3,6	14,76	1,4	18		372		
	vol 44							1545	4,15	1
7b	come 7b	p. 3°						132		
	pavimento		1,6 x 1,8	2,88	1,4	18		73		
	vol 9							205	0,55	1

S.T.I. — Ing. Fausto Felice — UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 10

Quartiere S. Elia - Brindisi

T_A 20°C T_E 2°C — Edificio tip 2 in linea - corpo A rif. plovim. 4CB - 5CB — Piano 1°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	come 9	piano 2°						1173		
	pavimento		4.1 x 3.6	14.76	1.4	18		372		
	Vol 44							1545	4.15	1
10	come 10	p. 2°						1092		
	pavimento		3.7 x 5.2	19.24	1.4	18		485		
	Vol 58							1577	4.15	1
11	come 11	p. 2°						193		
	pavimento		1.1 x 2.8	3.08	1.4	18		78		
	Vol 9							271	0.70	1
12	come 12	p. 2°						372		
	pavimento		1.7 x 3.8	4.46	1.4	18		163		
	Vol 19							535	1.40	1
13	come 13	p. 2°						643		
	pavimento		2.7 x 4.8	12.96	1.4	18		326		
	Vol 39							969	2.55	1
14	come 14	p. 2°						655		
	pavimento		3.7 x 3.8	14.06	1.4	18		354		
	Vol 42							1009	2.65	1
15	come 15	p. 2°						697		
	pavimento		3.7 x 4.8	17.76	1.4	18		447		
	Vol 53							1144	3.00	1
8	come 8	p. 2°						152		
	pavimento		1.6 x 1.8	2.88	1.4	18		73		
	Vol 9							225	0.60	1

S.I.L.	Ing Fausto Felix UFFICIO TECNICO	Progetto N. 704 Fascicolo A Pag. 10 Quartiere S. Elia - Baiolisi

TA 20°C TE 2°C — Edificio tip 2 in linea - corpo A rif. plovim. 4CB - 5CB — Piano 1°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
9	come 9	piano 2°						1173		
	pavimento		4.1 x 3.6	14.76	1.4	18		372		
	Vol 44							1545	4.15	1
10	come 10	p. 2°						1092		
	pavimento		3.7 x 5.2	19.24	1.4	18		485		
	Vol 58							1577	4.15	1
11	come 11	p. 2°						193		
	pavimento		1.1 x 2.8	3.08	1.4	18		78		
	Vol 9							271	0.70	1
12	come 12	p. 2°						372		
	pavimento		1.7 x 3.8	4.46	1.4	18		163		
	Vol 19							535	1.40	1
13	come 13	p. 2°						643		
	pavimento		2.7 x 4.8	12.96	1.4	18		326		
	Vol 39							969	2.55	1
14	come 14	p. 2°						655		
	pavimento		3.7 x 3.8	14.06	1.4	18		354		
	Vol 42							1009	2.65	1
15	come 15	p. 2°						697		
	pavimento		3.7 x 4.8	17.76	1.4	18		447		
	Vol 53							1144	3.00	1
8	come 8	p. 2°						152		
	pavimento		1.6 x 1.8	2.88	1.4	18		73		
	Vol 9							225	0.60	1

S.T.L. — Ing. Fausto Filisi — UFFICIO TECNICO

Progetto N: 704 Fascicolo A Pag. 10

Quartiere S. Elia - Brindisi

TA 2°C TE 2°C — Edificio tip 2 in linea - corpo A cif. plovim. 4CB - 5CB — Piano 1°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
9	come 9	piano 2°						1173		
	pavimento		4.1 x 3.6	14.76	1.4	18		372		
	Vol. 44							1545	4.15	1
10	come 10	p. 2°						1092		
	pavimento		3.7 x 5.2	19.24	1.4	18		485		
	Vol 58							1577	4.15	1
11	come 11	p. 2°						193		
	pavimento		1.1 x 2.8	3.08	1.4	18		78		
	Vol 9							271	0.70	1
12	come 12	p. 2°						372		
	pavimento		1.7 x 3.8	4.46	1.4	18		163		
	Vol 19							535	1.40	1
13	come 13	p. 2°						643		
	pavimento		2.7 x 4.8	12.96	1.4	18		326		
	Vol 39							969	2.55	1
14	come 14	p. 2°						655		
	pavimento		3.7 x 3.8	14.06	1.4	18		354		
	Vol 42							1009	2.65	1
15	come 15	p. 2°						697		
	pavimento		3.7 x 4.8	17.76	1.4	18		447		
	Vol 53							1144	3.00	1
8	come 8	p. 2°						152		
	pavimento		1.6 x 1.8	2.88	1.4	18		73		
	Vol 9							225	0.60	1

Edificio tip. 2 in linea - corpo B
rif. planim. 4CB - 5CB

T_A 20°C T_E 2°C

Piano 1°

Locali nº	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	S	3,8 x 3,8	11,40	1,2	18	1,15	283		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	pavimento		3,85 x 3,8	14,63	1,4	18		368		
	volume 3,85 x 3,8 x 3,0 = 44 x 0,3 x 18							237		
								1333	3,50	1
2	parete	S	4,9 x 3,0	14,70	1,2	18	1,15	365		
	parete	W	3,85 x 3,0	11,55	1,2	18	1,20	299		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		4,9 x 3,85	18,86	1,4	18		475		
	vol 4,9 x 3,85 x 3,0 = 57 x 0,3 x 18							306		
								1584	4,15	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	S	1,0 x 3,0	3,0	1,2	18	1,15	75		
	finestra	S	0,6 x 1,15	0,69	3,8	18	1,15	54		
	pavimento		1,7 x 3,8	6,46	1,4	18		163		
	vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							105		
								535	1,40	1
4	parete	N	1,0 x 3,0	3,0	1,2	18	1,30	84		
	parete	W	2,55 x 3,0	7,65	1,2	18	1,20	198		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		2,55 x 4,8	12,24	1,4	18		308		
	volume 2,55 x 4,8 x 3,0 = 37 x 0,3 x 18							198		
								927	2,45	1
5	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	pavimento		1,1 x 2,8	3,88	1,4	18		78		
	volume 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								271	0,70	1
6	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	pavimento		3,7 x 5,2	19,24	1,4	18		485		
	volume 3,7 x 5,2 x 3,0 = 58 x 0,3 x 18							312		
								1577	4,15	1

S.I.I.	Ing Fausto Falco UFFICIO TECNICO	Progetto N, 704 Fascicolo A Pag. 11 Quartiere S. Elia - Brindisi

TA 20°C TF 2°C — Edificio tip 2 in linea - corpo B zif. planim. 4CB - 5CB — Piano 1°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
1	parete	E	3,85 x 3,0	11,55	1,2	18	1,25	312		
	parete	S	3,8 x 3,8	11,40	1,2	18	1,15	283		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	pavimento		3,85 x 3,8	14,63	1,4	18		368		
	volume 3,85 x 3,8 x 3,0 = 44 x 0,3 x 18							237		
								1333	3,50	1
2	parete	S	4,9 x 3,0	14,70	1,2	18	1,15	365		
	parete	W	3,85 x 3,0	11,55	1,2	18	1,20	299		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		4,9 x 3,85	18,86	1,4	18		475		
	Vol 4,9 x 3,85 x 3,0 = 57 x 0,3 x 18							306		
								1584	4,15	1
3	parete	E	1,7 x 3,0	5,10	1,2	18	1,25	138		
	parete	S	1,0 x 3,0	3,0	1,2	18	1,15	75		
	finestra	S	0,6 x 1,15	0,69	3,8	18	1,15	54		
	pavimento		1,7 x 3,8	6,46	1,4	18		163		
	Vol 1,7 x 3,8 x 3,0 = 19 x 0,3 x 18							105		
								535	1,40	1
4	parete	N	1,0 x 3,0	3,0	1,2	18	1,30	84		
	parete	W	2,55 x 3,0	7,65	1,2	18	1,20	198		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		2,55 x 4,8	12,24	1,4	18		308		
	volume 2,55 x 4,8 x 3,0 = 37 x 0,3 x 18							198		
								927	2,45	1
5	parete	E	1,1 x 3,0	3,30	1,2	18	1,20	86		
	finestra	E	0,6 x 1,15	0,69	3,8	18	1,20	57		
	pavimento		1,1 x 2,8	3,88	1,4	18		78		
	Volume 1,1 x 2,8 x 3,0 = 9 x 0,3 x 18							50		
								271	0,70	1
6	parete	W	5,5 x 3,0	16,50	1,2	18	1,15	410		
	finestra	W	2 x 0,75 x 2,25	3,38	3,8	18	1,15	265		
	parete int		2,5 x 3,0	7,5	1,4	10		105		
	pavimento		3,7 x 5,2	19,24	1,4	18		485		
	Volume 3,7 x 5,2 x 3,0 = 58 x 0,3 x 18							312		
								1577	4,15	1

Ing. Fausto Falco

Quartiere S. Elia - Brindisi

Edificio tip. 2 in linea - corpo B
zif. planim. 4CB - 5CB

T_A 20°C T_F 2°C

Locali n°	struttura	esp.	Dimensioni mt.	Sur. mq.	K	ΔT	Aum. %	Cal/h	Piano 1 Stufe mq.	n.
7	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,0	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,60	1,4	10		176		
	pavimento		4,1 x 3,6	14,76	1,4	18		372		
	volume 4,1 x 3,6 x 3,0 = 44 x 0,3 x 18							239		
								1545	4,15	1
16	parete int.		1,6 x 3,0	4,80	1,4	10		67		
	porta int.		1,05 x 2,25	2,36	1,6	10		38		
	pavimento		1,6 x 1,8	2,88	1,4	18		73		
	volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								225	0,60	1
9	come 7		vol 44					1545	4,15	1
10	come 6		vol 58					1577	4,15	1
11	come 5		vol 9					271	0,70	1
12	come 3		vol 19					535	1,40	1
13	come 4		vol 37					927	2,45	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		3,7 x 3,8	14,06	1,4	18		354		
	vol 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								1009	2,65	1
15	parete	W	3,8 x 3,0	11,40	1,2	18	1,15	283		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	pavimento		3,8 x 4,8	18,24	1,4	18		460		
	vol 3,8 x 4,8 x 3,0 = 55 x 0,3 x 18							296		
								1172	3,10	1
	Totale piano 1°		vol	1043				30'205	79,80	31

Quartiere S. Elia - Brindisi

Edificio tipo 2 in linea - corpo B
cif. planim. 4CB - 5CB

T_A 20°C T_F 2°C

Piano 1

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	Δt	Aum. %	Cal/h	Stufe mq.	Stufe n.
7	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,0	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,60	1,4	10		176		
	pavimento		4,1 x 3,6	14,76	1,4	18		372		
	volume 4,1 x 3,6 x 3,0 = 44 x 0,3 x 18							239		
								1545	4,15	1
16	parete int.		1,6 x 3,0	4,80	1,4	10		67		
	porta int.		1,05 x 2,25	2,36	1,6	10		38		
	pavimento		1,6 x 1,8	2,88	1,4	18		73		
	volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								225	0,60	1
9	come 7		vol 44					1545	4,15	1
10	come 6		vol 58					1577	4,15	1
11	come 5		vol 9					271	0,70	1
12	come 3		vol 19					535	1,40	1
13	come 4		vol 37					927	2,45	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		3,7 x 3,8	14,06	1,4	18		354		
	vol 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								1009	2,65	1
15	parete	W	3,8 x 3,0	11,40	1,2	18	1,15	283		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	pavimento		3,8 x 4,8	18,24	1,4	18		460		
	vol 3,8 x 4,8 x 3,0 = 55 x 0,3 x 18							296		
								1172	3,10	1
	Totale piano 1°		vol	1043				30.205	79,80	31

S.T.I. — Ing. Faustino Falusi — UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 12

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
zif. planimetr. 4CB - 5CB

Piano 1

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
7	parete	E	4,1 x 3,0	12,30	1,2	18	1,25	332		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,25	144		
	parete	S	2,0 x 3,0	6,0	1,2	18	1,15	149		
	finestra	S	0,75 x 2,25	1,69	3,8	18	1,15	133		
	parete int.		4,2 x 3,0	12,60	1,4	10		176		
	pavimento		4,1 x 3,6	14,76	1,4	18		372		
	Volume 4,1 x 3,6 x 3,0 = 44 x 0,3 x 18							239		
								1545	4,15	1
16	parete int.		1,6 x 3,0	4,80	1,4	10		67		
	porta int.		1,05 x 2,25	2,36	1,6	10		38		
	pavimento		1,6 x 1,8	2,88	1,4	18		73		
	Volume 1,6 x 1,8 x 3,0 = 9 x 0,3 x 18							47		
								225	0,60	1
9	come 7		vol 44					1545	4,15	1
10	come 6		vol 58					1577	4,15	1
11	come 5		vol 9					271	0,70	1
12	come 3		vol 19					535	1,40	1
13	come 4		vol 37					927	2,45	1
14	parete	E	3,7 x 3,0	11,10	1,2	18	1,20	288		
	finestra	E	0,75 x 2,25	1,69	3,8	18	1,20	139		
	pavimento		3,7 x 3,8	14,06	1,4	18		354		
	vol 3,7 x 3,8 x 3,0 = 42 x 0,3 x 18							228		
								1009	2,65	1
15	parete	W	3,8 x 3,0	11,40	1,2	18	1,15	283		
	finestra	W	0,75 x 2,25	1,69	3,8	18	1,15	133		
	pavimento		3,8 x 4,8	18,24	1,4	18		460		
	vol 3,8 x 4,8 x 3,0 = 55 x 0,3 x 18							296		
								1172	3,10	1
	Totale piano 1°		vol	1043				30'205	79,80	31

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo A
ciel. blocchi 4CB - 5CB

Piano 4°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
1	come 1 p.	2°						1019		
	copertura		3.8 x 3.85	14.63	1.5	18		395		
	vol 44							1414	3.70	1
2	come 2 p	2°						944		
	copertura		3.55 x 3.7	13.10	1.5	18		355		
	vol 39							1299	3.42	1
3	come 3 p.	2°						372		
	copertura		1.7 x 3.8	6.46	1.5	18		175		
	vol 19							547	1.45	1
4	come 4 p.	2°						456		
	copertura		3.7 x 2.4	8.88	1.5	18		240		
	vol 27							696	1.85	1
5	come 5 p.	2°						1162		
	copertura		4.0 x 3.5	14.00	1.5	18		378		
	vol 42							1540	4.05	1
6	come 6 p.	2°						998		
	copertura		3.7 x 4.5	16.65	1.5	18		449		
	vol 50							1447	3.80	1
7	come 7 p.	2°						152		
	copertura		1.6 x 1.8	2.88	1.5	18		78		
	vol 9							230	0.60	1
8	come 8 p.	2°						152		
	copertura		1.6 x 1.8	2.88	1.5	18		78		
	vol 9							230	0.60	1
9	come 9 p.	2°						1173		
	copertura		4.1 x 3.6	14.76	1.5	18		398		
	vol 44							1571	4.15	1
10	come 10 p.	2°						1092		
	copertura		3.7 x 5.2	19.24	1.5	18		519		
	vol 58							1611	4.20	1
11	come 11 p.	2°						193		
	copertura		1.1 x 2.8	3.88	1.5	18		83		
	vol 9							276	0.70	1

TA 20°C TE 2°C

Edificio tipo 2 in linea - corpo A
vil. plurim. 4 C B - 5 C B

Piano 4°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
1	come 1 p.	2°						1019		
	copertura		3.8 x 3.85	14.63	1.5	18		395		
	vol 44							1414	3.70	1
2	come 2 p	2°						944		
	copertura		3.55 x 3.7	13.10	1.5	18		355		
	vol 39							1299	3.42	1
3	come 3 p.	2°						372		
	copertura		1.7 x 3.8	6.46	1.5	18		175		
	vol 19							547	1.45	1
4	come 4 p.	2°						456		
	copertura		3.7 x 2.4	8.88	1.5	18		240		
	vol 27							696	1.85	1
5	come 5 p.	2°						1162		
	copertura		4.0 x 3.5	14.00	1.5	18		378		
	vol 42							1540	4.05	1
6	come 6 p.	2°						998		
	copertura		3.7 x 4.5	16.65	1.5	18		449		
	vol 50							1447	3.80	1
7	come 7 p.	2°						152		
	copertura		1.6 x 1.8	2.88	1.5	18		78		
	vol 9							230	0.60	1
8	come 8 p.	2°						152		
	copertura		1.6 x 1.8	2.88	1.5	18		78		
	vol 9							230	0.60	1
9	come 9 p.	2°						1173		
	copertura		4.1 x 3.6	14.76	1.5	18		398		
	vol 44							1571	4.15	1
10	come 10 p.	2°						1092		
	copertura		3.7 x 5.2	19.24	1.5	18		519		
	vol 58							1611	4.20	1
11	come 11 p.	2°						193		
	copertura		1.1 x 2.8	3.88	1.5	18		83		
	vol 9							276	0.70	1

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo A
cil. plenum. 4CB - 5CB

Piano 4°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	come 1 p.	2°						1019		
	copertura		3.8 x 3.85	14.63	1.5	18		395		
	vol 44							1414	3.70	1
2	come 2 p	2°						944		
	copertura		3.55 x 3.7	13.10	1.5	18		355		
	vol 39							1299	3.42	1
3	come 3 p.	2°						372		
	copertura		1.7 x 3.8	6.46	1.5	18		175		
	vol 19							547	1.45	1
4	come 4 p.	2°						456		
	copertura		3.7 x 2.4	8.88	1.5	18		240		
	vol 27							696	1.85	1
5	come 5 p.	2°						1162		
	copertura		4.0 x 3.5	14.00	1.5	18		378		
	vol 42							1540	4.05	1
6	come 6 p.	2°						998		
	copertura		3.7 x 4.5	16.65	1.5	18		449		
	vol 50							1447	3.80	1
7	come 7 p.	2°						152		
	copertura		1.6 x 1.8	2.88	1.5	18		78		
	vol 9							230	0.60	1
8	come 8 p.	2°						152		
	copertura		1.6 x 1.8	2.88	1.5	18		78		
	vol 9							230	0.60	1
9	come 9 p.	2°						1173		
	copertura		4.1 x 3.6	14.76	1.5	18		398		
	vol 44							1571	4.15	1
10	come 10 p.	2°						1092		
	copertura		3.7 x 5.2	19.24	1.5	18		519		
	vol 58							1611	4.20	1
11	come 11 p.	2°						193		
	copertura		1.1 x 2.8	3.08	1.5	18		83		
	vol 9							276	0.70	1

TA 20°C TF 2°C

Edificio tipo 2 in linea - corpo A
tip. plurim. 4CB - 5CB

Piano 4°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
12	come 12	p.	2°					372		
	copertura		1,7 x 3,8	6,46	1,5	18		174		
	Vol 19							546	1,45	1
13	come 13	p.	2°					643		
	copertura		2,7 x 4,8	12,96	1,5	18		350		
	Vol 39							993	2,60	1
14	come 14	p.	2°					655		
	copertura		3,7 x 3,8	14,06	1,5	18		380		
	Vol 42							1035	2,72	1
15	come 15	p.	2°					697		
	copertura		3,7 x 4,8	17,76	1,5	18		480		
	Vol 53							1177	3,10	1

S.I.I. Ing Fausto Falco
UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 14

Quartiere S.Elia - Brindisi

T_A 20°C T_E 2°C

Edificio tipo 2 in linea - corpo A
zil. plomim. 4CB - 5CB

Piano 4°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
12	come 12	p.	2°					372		
	copertura		1,7 x 3,8	6,46	1,5	18		174		
	Vol 19							546	1,45	1
13	come 13	p.	2°					643		
	copertura		2,7 x 4,8	12,96	1,5	18		350		
	Vol 39							993	2,60	1
14	come 14	p.	2°					655		
	copertura		3,7 x 3,8	14,06	1,5	18		380		
	Vol 42							1035	2,72	1
15	come 15	p.	2°					697		
	copertura		3,7 x 4,8	17,76	1,5	18		480		
	Vol 53							1177	3,10	1

S.I.I. — Ing. Fausto Farina — UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 14

Quartiere S.Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo A
tip. planim. 4CB - 5CB

Piano 4°

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
12	come 12	p.	2°					372		
	copertura		1,7 x 3,8	6,46	1,5	18		174		
	Vol 19							546	1,45	1
13	come 13	p.	2°					643		
	copertura		2,7 x 4,8	12,96	1,5	18		350		
	Vol 39							993	2,60	1
14	come 14	p. 2°						655		
	copertura		3,7 x 3,8	14,06	1,5	18		380		
	Vol 42							1035	2,72	1
15	come 15	p. 2°						697		
	copertura		3,7 x 4,8	17,76	1,5	18		480		
	Vol 53							1177	3,10	1

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
cif. planim. 4CB - 5CB

Piano 4°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	come 1 p. 2°							965		
	copertura		3,85 x 3,8	14,6	1,5	18		395		
								1360	3,60	1
2	come 2 p. 2°							904		
	copertura		3,55 x 3,7	13,10	1,5	18		354		
								1258	3,30	1
3	come 3 p. 2°							372		
	copertura		1,7 x 3,8	6,46	1,5	18		174		
								546	1,44	1
4	come 4 p. 2°							456		
	copertura		2,4 x 3,7	8,88	1,5	18		240		
								686	1,80	1
5	come 5 p. 2°							1016		
	copertura		4,8 x 3,7	17,76	1,5	18		479		
								1495	3,95	1
6	come 6 p. 2°							152		
	copertura		1,6 x 1,8	2,88	1,5	18		78		
								230	0,60	1
7	come 7 p. 2°							1104		
	copertura		4,0 x 3,5	14,0	1,5	18		378		
								1482	3,95	1
9	come 7							1482	3,95	1
10	come 10 p. 2°							1092		
	copertura		3,7 x 5,2	19,20	1,5	18		519		
								1611	4,25	1
11	come 11 p. 2°							193		
	copertura		1,1 x 2,8	3,08	1,5	18		83		
								276	0,70	1
12	come 3							546	1,44	1
13	come 13 p. 2°							643		
	copertura		2,7 x 4,8	12,96	1,5	18		350		
								993	2,60	1

S.T.I. Ing Fausto Falva UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 15

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
cif. planim. 4CB - 5CB

Piano 4°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	come 1 p. 2°							965		
	copertura		3,85 x 3,8	14,6	1,5	18		395		
								1360	3,60	1
2	come 2 p. 2°							904		
	copertura		3,55 x 3,7	13,10	1,5	18		354		
								1258	3,30	1
3	come 3 p. 2°							372		
	copertura		1,7 x 3,8	6,46	1,5	18		174		
								546	1,44	1
4	come 4 p. 2°							456		
	copertura		2,4 x 3,7	8,88	1,5	18		240		
								686	1,80	1
5	come 5 p. 2°							1016		
	copertura		4,8 x 3,7	17,76	1,5	18		479		
								1495	3,95	1
6	come 6 p 2°							152		
	copertura		1,6 x 1,8	2,88	1,5	18		78		
								230	0,60	1
7	come 7 p 2°							1104		
	copertura		4,0 x 3,5	14,0	1,5	18		378		
								1482	3,95	1
9	come 7							1482	3,95	1
10	come 10 p. 2°							1092		
	copertura		3,7 x 5,2	19,20	1,5	18		519		
								1611	4,20	1
11	come 11 p. 2°							193		
	copertura		1,1 x 2,8	3,08	1,5	18		83		
								276	0,70	1
12	come 3							546	1,44	1
13	come 13 p. 2°							643		
	copertura		2,7 x 4,8	12,96	1,5	18		350		
								993	2,60	1

S.T.I. — Ing. Fausto Falvo — UFFICIO TECNICO

Progetto N. 704 Fascicolo A Pag. 15

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tipo 2 in linea - corpo B
cif. planim. 4CB - 5CB

Piano 4°

Locali n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	Stufe mq.	Stufe n.
1	come 1 p. 2°							965		
	copertura		3,85 x 3,8	14,6	1,5	18		395		
								1360	3,60	1
2	come 2 p. 2°							904		
	copertura		3,55 x 3,7	13,10	1,5	18		354		
								1258	3,30	1
3	come 3 p. 2°							372		
	copertura		1,7 x 3,8	6,46	1,5	18		174		
								546	1,44	1
4	come 4 p. 2°							456		
	copertura		2,4 x 3,7	8,88	1,5	18		240		
								686	1,80	1
5	come 5 p. 2°							1016		
	copertura		4,8 x 3,7	17,76	1,5	18		479		
								1495	3,95	1
6	come 6 p. 2°							152		
	copertura		1,6 x 1,8	2,88	1,5	18		78		
								230	0,60	1
7	come 7 p. 2°							1104		
	copertura		4,0 x 3,5	14,0	1,5	18		378		
								1482	3,95	1
9	come 7							1482	3,95	1
10	come 10 p. 2°							1092		
	copertura		3,7 x 5,2	19,20	1,5	18		519		
								1611	4,20	1
11	come 11 p. 2°							193		
	copertura		1,1 x 2,8	3,08	1,5	18		83		
								276	0,70	1
12	come 3							546	1,44	1
13	come 13 p. 2°							643		
	copertura		2,7 x 4,8	12,96	1,5	18		350		
								993	2,60	1

Quartiere S. Elia - Brindisi

T_A 20°C T_F 2°C

Edificio tip 2 in linea - Corpo B
rif. planim. 4CB - 5CB

Piano 4

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
14	come 14	p.2°						655		
	copertura		3,7 x 3,8	14.06	1,5	18		379		
								1034	2,70	1
15	come 15	p 2°						697		
	copertura		3,7 x 4,8	17,76	1,5	18		479		
								1176	3,10	1
16	come 6							230	0,60	1
	Totale piano 4°		vol 1011					29017	76,32	30
	Totale Fabbricato		vol	4119				99.654	262,73	122

T_A 20°C T_E 2°C

Edificio tip 2 in linea - Corpo B
rif. planim. 4 C B - 5 C B

Piano 4

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
14	come 14	p.2°						655		
	copertura		3,7 x 3,8	14.06	1,5	18		379		
								1034	2,70	1
15	come 15	p 2°						697		
	copertura		3,7 x 4,8	17,76	1,5	18		479		
								1176	3,10	1
16	come 6							230	0,60	1
	Totale piano 4°		vol 1011					29017	76,32	30
	Totale Fabbricato		vol	4119				99.654	262,75	122

T_A 20°C T_F 2°C

Edificio tip 2 in linea - Corpo B
rif. planim. 4CB - 5CB

Piano 4

Locali									Stufe	
n°	struttura	esp.	Dimensioni mt.	Sup. mq.	K	ΔT	Aum. %	Cal/h	mq.	n.
14	come 14	p.2°						655		
	copertura		3,7 x 3,8	14.06	1,5	18		379		
								1034	2,70	1
15	come 15	p 2°						697		
	copertura		3.7 x 4,8	17,76	1,5	18		479		
								1176	3,10	1
16	come 6							230	0,60	1
	Totale piano 4°		vol 1011					29017	76,32	30
	Totale Fabbricato		vol	4119				99.654	262,73	122