

FOSSA SETTICA A QUATTRO CAMERE

A



30/08.1971

PROGETTO: DAZZI LORENZO e MARIA

IL TECNICO:



Lucio Branai



SEZIONE A-B

no 2

N° VANI UTILI	N° PERSONE	CONSUMO MEDIO GIORNAL. LITRI	DIMENSIONI SUGGERITE						
			LUNGHEZZE				LARGHEZZA	ALTEZZA LIQUIDO	ALTEZZA TOTALE INTERNA
			1a CAMERA	2a CAMERA	3a CAMERA	4a CAMERA			
Δ	B	C	D	I	h	H			
14	20	2000	2.20	1.10	1.10	1.65	1.10	1.40	1.75
27	40	4000	2.50	1.25	1.25	1.90	1.50	1.55	1.90
40	60	6000	3.00	1.50	1.50	2.25	1.80	1.60	1.95
54	80	8000	3.50	1.75	1.75	2.60	2.00	1.60	1.95